



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

# BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

## Listing Information

Vendor		Listing Status
FieldServer Technologies 1991 Tarob Court Milpitas, California 95035 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 12 (135-2010)	January 2014

Product Name	Model Number(s)	Software Version
QuickServer	FS-QS-1XXX	12
ProtoCessor	FPC-F03	12
ProtoCessor	FPC-ED2	12
ProtoCessor	FPC-ED4	12
ProtoCarrier	FPC-CXX	12
ProtoNode	FPC-NXX	12

## Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

Alarm and Event Management	Alarm and Event-Notification Internal-B	AE-N-I-B
	Alarm and Event-ACK-B	AE-ACK-B
	Alarm and Event-Information-B	AE-INFO-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
----------	---	-----------

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B
	ListManipulation-B	DM-LM-B

### Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Multi-state Input	Multi-state Output	Multi-state Value
Notification Class	Device	Trend Log

### Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800
BACnet/IP (Annex J)	BBMD

### Character Set Support

ANSI X3.4 / UTF-8
-------------------